

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/280/25	Model No.: MARQ-6-50%	Date: 05-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 280/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27901 To 28000 And 27905A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27905A and removed from the Lot/Batch							
27901	Pass	27902	Pass	27903	Pass	27904	Pass
27905	Pass	27906	Pass	27907	Pass	27908	Pass
27909	Pass	27910	Pass	27911	Pass	27912	Pass
27913	Pass	27914	Pass	27915	Pass	27916	Pass
27917	Pass	27918	Pass	27919	Pass	27920	Pass
27921	Pass	27922	Pass	27923	Pass	27924	Pass
27925	Pass	27926	Pass	27927	Pass	27928	Pass
27929	Pass	27930	Pass	27931	Pass	27932	Pass
27933	Pass	27934	Pass	27935	Pass	27936	Pass
27937	Pass	27938	Pass	27939	Pass	27940	Pass
27941	Pass	27942	Pass	27943	Pass	27944	Pass
27945	Pass	27946	Pass	27947	Pass	27948	Pass
27949	Pass	27950	Pass	27951	Pass	27952	Pass
27953	Pass	27954	Pass	27955	Pass	27956	Pass
27957	Pass	27958	Pass	27959	Pass	27960	Pass
27961	Pass	27962	Pass	27963	Pass	27964	Pass
27965	Pass	27966	Pass	27967	Pass	27968	Pass
27969	Pass	27970	Pass	27971	Pass	27972	Pass
27973	Pass	27974	Pass	27975	Pass	27976	Pass
27977	Pass	27978	Pass	27979	Pass	27980	Pass
27981	Pass	27982	Pass	27983	Pass	27984	Pass
27985	Pass	27986	Pass	27987	Pass	27988	Pass
27989	Pass	27990	Pass	27991	Pass	27992	Pass
27993	Pass	27994	Pass	27995	Pass	27996	Pass
27997	Pass	27998	Pass	27999	Pass	28000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory