

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/314/25     | Model No.: MARQ-6-50%                                          | Date: 10-10-2025 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 314/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 31301 To 31400 And 31305A                                    |                  |
| Month of Manufacturing            | : Oct/25                                                       |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 31305A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 31301                                                         | Pass   | 31302    | Pass   | 31303    | Pass   | 31304    | Pass   |
| 31305                                                         | Pass   | 31306    | Pass   | 31307    | Pass   | 31308    | Pass   |
| 31309                                                         | Pass   | 31310    | Pass   | 31311    | Pass   | 31312    | Pass   |
| 31313                                                         | Pass   | 31314    | Pass   | 31315    | Pass   | 31316    | Pass   |
| 31317                                                         | Pass   | 31318    | Pass   | 31319    | Pass   | 31320    | Pass   |
| 31321                                                         | Pass   | 31322    | Pass   | 31323    | Pass   | 31324    | Pass   |
| 31325                                                         | Pass   | 31326    | Pass   | 31327    | Pass   | 31328    | Pass   |
| 31329                                                         | Pass   | 31330    | Pass   | 31331    | Pass   | 31332    | Pass   |
| 31333                                                         | Pass   | 31334    | Pass   | 31335    | Pass   | 31336    | Pass   |
| 31337                                                         | Pass   | 31338    | Pass   | 31339    | Pass   | 31340    | Pass   |
| 31341                                                         | Pass   | 31342    | Pass   | 31343    | Pass   | 31344    | Pass   |
| 31345                                                         | Pass   | 31346    | Pass   | 31347    | Pass   | 31348    | Pass   |
| 31349                                                         | Pass   | 31350    | Pass   | 31351    | Pass   | 31352    | Pass   |
| 31353                                                         | Pass   | 31354    | Pass   | 31355    | Pass   | 31356    | Pass   |
| 31357                                                         | Pass   | 31358    | Pass   | 31359    | Pass   | 31360    | Pass   |
| 31361                                                         | Pass   | 31362    | Pass   | 31363    | Pass   | 31364    | Pass   |
| 31365                                                         | Pass   | 31366    | Pass   | 31367    | Pass   | 31368    | Pass   |
| 31369                                                         | Pass   | 31370    | Pass   | 31371    | Pass   | 31372    | Pass   |
| 31373                                                         | Pass   | 31374    | Pass   | 31375    | Pass   | 31376    | Pass   |
| 31377                                                         | Pass   | 31378    | Pass   | 31379    | Pass   | 31380    | Pass   |
| 31381                                                         | Pass   | 31382    | Pass   | 31383    | Pass   | 31384    | Pass   |
| 31385                                                         | Pass   | 31386    | Pass   | 31387    | Pass   | 31388    | Pass   |
| 31389                                                         | Pass   | 31390    | Pass   | 31391    | Pass   | 31392    | Pass   |
| 31393                                                         | Pass   | 31394    | Pass   | 31395    | Pass   | 31396    | Pass   |
| 31397                                                         | Pass   | 31398    | Pass   | 31399    | Pass   | 31400    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**