

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/058/25	Model No.: MARQ-4-50%	Date: 27-07-2025
Type and Capacity of Extinguisher	: MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ50%4 058/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05701 To 5800 And 5705A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5705A and removed from the Lot/Batch							
5701	Pass	5702	Pass	5703	Pass	5704	Pass
5705	Pass	5706	Pass	5707	Pass	5708	Pass
5709	Pass	5710	Pass	5711	Pass	5712	Pass
5713	Pass	5714	Pass	5715	Pass	5716	Pass
5717	Pass	5718	Pass	5719	Pass	5720	Pass
5721	Pass	5722	Pass	5723	Pass	5724	Pass
5725	Pass	5726	Pass	5727	Pass	5728	Pass
5729	Pass	5730	Pass	5731	Pass	5732	Pass
5733	Pass	5734	Pass	5735	Pass	5736	Pass
5737	Pass	5738	Pass	5739	Pass	5740	Pass
5741	Pass	5742	Pass	5743	Pass	5744	Pass
5745	Pass	5746	Pass	5747	Pass	5748	Pass
5749	Pass	5750	Pass	5751	Pass	5752	Pass
5753	Pass	5754	Pass	5755	Pass	5756	Pass
5757	Pass	5758	Pass	5759	Pass	5760	Pass
5761	Pass	5762	Pass	5763	Pass	5764	Pass
5765	Pass	5766	Pass	5767	Pass	5768	Pass
5769	Pass	5770	Pass	5771	Pass	5772	Pass
5773	Pass	5774	Pass	5775	Pass	5776	Pass
5777	Pass	5778	Pass	5779	Pass	5780	Pass
5781	Pass	5782	Pass	5783	Pass	5784	Pass
5785	Pass	5786	Pass	5787	Pass	5788	Pass
5789	Pass	5790	Pass	5791	Pass	5792	Pass
5793	Pass	5794	Pass	5795	Pass	5796	Pass
5797	Pass	5798	Pass	5799	Pass	5800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory