

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/281/25	Model No.: MARQ-6-50%	Date: 05-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 281/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28001 To 28100 And 28005A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28005A and removed from the Lot/Batch							
28001	Pass	28002	Pass	28003	Pass	28004	Pass
28005	Pass	28006	Pass	28007	Pass	28008	Pass
28009	Pass	28010	Pass	28011	Pass	28012	Pass
28013	Pass	28014	Pass	28015	Pass	28016	Pass
28017	Pass	28018	Pass	28019	Pass	28020	Pass
28021	Pass	28022	Pass	28023	Pass	28024	Pass
28025	Pass	28026	Pass	28027	Pass	28028	Pass
28029	Pass	28030	Pass	28031	Pass	28032	Pass
28033	Pass	28034	Pass	28035	Pass	28036	Pass
28037	Pass	28038	Pass	28039	Pass	28040	Pass
28041	Pass	28042	Pass	28043	Pass	28044	Pass
28045	Pass	28046	Pass	28047	Pass	28048	Pass
28049	Pass	28050	Pass	28051	Pass	28052	Pass
28053	Pass	28054	Pass	28055	Pass	28056	Pass
28057	Pass	28058	Pass	28059	Pass	28060	Pass
28061	Pass	28062	Pass	28063	Pass	28064	Pass
28065	Pass	28066	Pass	28067	Pass	28068	Pass
28069	Pass	28070	Pass	28071	Pass	28072	Pass
28073	Pass	28074	Pass	28075	Pass	28076	Pass
28077	Pass	28078	Pass	28079	Pass	28080	Pass
28081	Pass	28082	Pass	28083	Pass	28084	Pass
28085	Pass	28086	Pass	28087	Pass	28088	Pass
28089	Pass	28090	Pass	28091	Pass	28092	Pass
28093	Pass	28094	Pass	28095	Pass	28096	Pass
28097	Pass	28098	Pass	28099	Pass	28100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory