

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/270/25	Model No.: KFARQ-6-50%	Date: 18-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 270/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26901 To 27000 And 26905A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26905A and removed from the Lot/Batch							
26901	Pass	26902	Pass	26903	Pass	26904	Pass
26905	Pass	26906	Pass	26907	Pass	26908	Pass
26909	Pass	26910	Pass	26911	Pass	26912	Pass
26913	Pass	26914	Pass	26915	Pass	26916	Pass
26917	Pass	26918	Pass	26919	Pass	26920	Pass
26921	Pass	26922	Pass	26923	Pass	26924	Pass
26925	Pass	26926	Pass	26927	Pass	26928	Pass
26929	Pass	26930	Pass	26931	Pass	26932	Pass
26933	Pass	26934	Pass	26935	Pass	26936	Pass
26937	Pass	26938	Pass	26939	Pass	26940	Pass
26941	Pass	26942	Pass	26943	Pass	26944	Pass
26945	Pass	26946	Pass	26947	Pass	26948	Pass
26949	Pass	26950	Pass	26951	Pass	26952	Pass
26953	Pass	26954	Pass	26955	Pass	26956	Pass
26957	Pass	26958	Pass	26959	Pass	26960	Pass
26961	Pass	26962	Pass	26963	Pass	26964	Pass
26965	Pass	26966	Pass	26967	Pass	26968	Pass
26969	Pass	26970	Pass	26971	Pass	26972	Pass
26973	Pass	26974	Pass	26975	Pass	26976	Pass
26977	Pass	26978	Pass	26979	Pass	26980	Pass
26981	Pass	26982	Pass	26983	Pass	26984	Pass
26985	Pass	26986	Pass	26987	Pass	26988	Pass
26989	Pass	26990	Pass	26991	Pass	26992	Pass
26993	Pass	26994	Pass	26995	Pass	26996	Pass
26997	Pass	26998	Pass	26999	Pass	27000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory