

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/325/25	Model No.: MARQ-6-50%	Date: 16-11-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 325/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 32401 To 32500 And 32405A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 32405A and removed from the Lot/Batch							
32401	Pass	32402	Pass	32403	Pass	32404	Pass
32405	Pass	32406	Pass	32407	Pass	32408	Pass
32409	Pass	32410	Pass	32411	Pass	32412	Pass
32413	Pass	32414	Pass	32415	Pass	32416	Pass
32417	Pass	32418	Pass	32419	Pass	32420	Pass
32421	Pass	32422	Pass	32423	Pass	32424	Pass
32425	Pass	32426	Pass	32427	Pass	32428	Pass
32429	Pass	32430	Pass	32431	Pass	32432	Pass
32433	Pass	32434	Pass	32435	Pass	32436	Pass
32437	Pass	32438	Pass	32439	Pass	32440	Pass
32441	Pass	32442	Pass	32443	Pass	32444	Pass
32445	Pass	32446	Pass	32447	Pass	32448	Pass
32449	Pass	32450	Pass	32451	Pass	32452	Pass
32453	Pass	32454	Pass	32455	Pass	32456	Pass
32457	Pass	32458	Pass	32459	Pass	32460	Pass
32461	Pass	32462	Pass	32463	Pass	32464	Pass
32465	Pass	32466	Pass	32467	Pass	32468	Pass
32469	Pass	32470	Pass	32471	Pass	32472	Pass
32473	Pass	32474	Pass	32475	Pass	32476	Pass
32477	Pass	32478	Pass	32479	Pass	32480	Pass
32481	Pass	32482	Pass	32483	Pass	32484	Pass
32485	Pass	32486	Pass	32487	Pass	32488	Pass
32489	Pass	32490	Pass	32491	Pass	32492	Pass
32493	Pass	32494	Pass	32495	Pass	32496	Pass
32497	Pass	32498	Pass	32499	Pass	32500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory