

HYDRO PRESSURE TEST

TC No.: HPT/W45/RQ/015/25	Model No.: KFWRQ-45	Date: 18-11-2025
Type and Capacity of Extinguisher	: KFWRQ-45-Kanex Water Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFWRQ45 015/25	
Batch Quantity	: 6.00 Nos.	
Serial Numbers	: 00071 To 75 And 75A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 75A and removed from the Lot/Batch							
71	Pass	72	Pass	73	Pass	74	Pass
75	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory