

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/164/25	Model No.: MARQ-6-40%	Date: 08-09-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 164/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 16301 To 16400 And 16305A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 16305A and removed from the Lot/Batch							
16301	Pass	16302	Pass	16303	Pass	16304	Pass
16305	Pass	16306	Pass	16307	Pass	16308	Pass
16309	Pass	16310	Pass	16311	Pass	16312	Pass
16313	Pass	16314	Pass	16315	Pass	16316	Pass
16317	Pass	16318	Pass	16319	Pass	16320	Pass
16321	Pass	16322	Pass	16323	Pass	16324	Pass
16325	Pass	16326	Pass	16327	Pass	16328	Pass
16329	Pass	16330	Pass	16331	Pass	16332	Pass
16333	Pass	16334	Pass	16335	Pass	16336	Pass
16337	Pass	16338	Pass	16339	Pass	16340	Pass
16341	Pass	16342	Pass	16343	Pass	16344	Pass
16345	Pass	16346	Pass	16347	Pass	16348	Pass
16349	Pass	16350	Pass	16351	Pass	16352	Pass
16353	Pass	16354	Pass	16355	Pass	16356	Pass
16357	Pass	16358	Pass	16359	Pass	16360	Pass
16361	Pass	16362	Pass	16363	Pass	16364	Pass
16365	Pass	16366	Pass	16367	Pass	16368	Pass
16369	Pass	16370	Pass	16371	Pass	16372	Pass
16373	Pass	16374	Pass	16375	Pass	16376	Pass
16377	Pass	16378	Pass	16379	Pass	16380	Pass
16381	Pass	16382	Pass	16383	Pass	16384	Pass
16385	Pass	16386	Pass	16387	Pass	16388	Pass
16389	Pass	16390	Pass	16391	Pass	16392	Pass
16393	Pass	16394	Pass	16395	Pass	16396	Pass
16397	Pass	16398	Pass	16399	Pass	16400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory