

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/296/25	Model No.: MARQ-6-50%	Date: 22-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 296/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29501 To 29600 And 29505A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29505A and removed from the Lot/Batch							
29501	Pass	29502	Pass	29503	Pass	29504	Pass
29505	Pass	29506	Pass	29507	Pass	29508	Pass
29509	Pass	29510	Pass	29511	Pass	29512	Pass
29513	Pass	29514	Pass	29515	Pass	29516	Pass
29517	Pass	29518	Pass	29519	Pass	29520	Pass
29521	Pass	29522	Pass	29523	Pass	29524	Pass
29525	Pass	29526	Pass	29527	Pass	29528	Pass
29529	Pass	29530	Pass	29531	Pass	29532	Pass
29533	Pass	29534	Pass	29535	Pass	29536	Pass
29537	Pass	29538	Pass	29539	Pass	29540	Pass
29541	Pass	29542	Pass	29543	Pass	29544	Pass
29545	Pass	29546	Pass	29547	Pass	29548	Pass
29549	Pass	29550	Pass	29551	Pass	29552	Pass
29553	Pass	29554	Pass	29555	Pass	29556	Pass
29557	Pass	29558	Pass	29559	Pass	29560	Pass
29561	Pass	29562	Pass	29563	Pass	29564	Pass
29565	Pass	29566	Pass	29567	Pass	29568	Pass
29569	Pass	29570	Pass	29571	Pass	29572	Pass
29573	Pass	29574	Pass	29575	Pass	29576	Pass
29577	Pass	29578	Pass	29579	Pass	29580	Pass
29581	Pass	29582	Pass	29583	Pass	29584	Pass
29585	Pass	29586	Pass	29587	Pass	29588	Pass
29589	Pass	29590	Pass	29591	Pass	29592	Pass
29593	Pass	29594	Pass	29595	Pass	29596	Pass
29597	Pass	29598	Pass	29599	Pass	29600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory