

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/071/25	Model No.: KFARQ-2-90%	Date: 12-07-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 071/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07001 To 7100 And 7005A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7005A and removed from the Lot/Batch							
7001	Pass	7002	Pass	7003	Pass	7004	Pass
7005	Pass	7006	Pass	7007	Pass	7008	Pass
7009	Pass	7010	Pass	7011	Pass	7012	Pass
7013	Pass	7014	Pass	7015	Pass	7016	Pass
7017	Pass	7018	Pass	7019	Pass	7020	Pass
7021	Pass	7022	Pass	7023	Pass	7024	Pass
7025	Pass	7026	Pass	7027	Pass	7028	Pass
7029	Pass	7030	Pass	7031	Pass	7032	Pass
7033	Pass	7034	Pass	7035	Pass	7036	Pass
7037	Pass	7038	Pass	7039	Pass	7040	Pass
7041	Pass	7042	Pass	7043	Pass	7044	Pass
7045	Pass	7046	Pass	7047	Pass	7048	Pass
7049	Pass	7050	Pass	7051	Pass	7052	Pass
7053	Pass	7054	Pass	7055	Pass	7056	Pass
7057	Pass	7058	Pass	7059	Pass	7060	Pass
7061	Pass	7062	Pass	7063	Pass	7064	Pass
7065	Pass	7066	Pass	7067	Pass	7068	Pass
7069	Pass	7070	Pass	7071	Pass	7072	Pass
7073	Pass	7074	Pass	7075	Pass	7076	Pass
7077	Pass	7078	Pass	7079	Pass	7080	Pass
7081	Pass	7082	Pass	7083	Pass	7084	Pass
7085	Pass	7086	Pass	7087	Pass	7088	Pass
7089	Pass	7090	Pass	7091	Pass	7092	Pass
7093	Pass	7094	Pass	7095	Pass	7096	Pass
7097	Pass	7098	Pass	7099	Pass	7100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory