

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/086/25

Model No.: KFKHQ-6

Date: 23-09-2025

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 086/25

Batch Quantity : 10 Nos.

Serial Numbers : 00851 To 860

Month of Manufacturing : Sep/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
851	Pass	852	Pass	853	Pass	854	Pass
855	Pass	856	Pass	857	Pass	858	Pass
859	Pass	860	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**