

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/206/25	Model No.: KFARQ-6-50%	Date: 21-06-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 206/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20501 To 20600 And 20505A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20505A and removed from the Lot/Batch							
20501	Pass	20502	Pass	20503	Pass	20504	Pass
20505	Pass	20506	Pass	20507	Pass	20508	Pass
20509	Pass	20510	Pass	20511	Pass	20512	Pass
20513	Pass	20514	Pass	20515	Pass	20516	Pass
20517	Pass	20518	Pass	20519	Pass	20520	Pass
20521	Pass	20522	Pass	20523	Pass	20524	Pass
20525	Pass	20526	Pass	20527	Pass	20528	Pass
20529	Pass	20530	Pass	20531	Pass	20532	Pass
20533	Pass	20534	Pass	20535	Pass	20536	Pass
20537	Pass	20538	Pass	20539	Pass	20540	Pass
20541	Pass	20542	Pass	20543	Pass	20544	Pass
20545	Pass	20546	Pass	20547	Pass	20548	Pass
20549	Pass	20550	Pass	20551	Pass	20552	Pass
20553	Pass	20554	Pass	20555	Pass	20556	Pass
20557	Pass	20558	Pass	20559	Pass	20560	Pass
20561	Pass	20562	Pass	20563	Pass	20564	Pass
20565	Pass	20566	Pass	20567	Pass	20568	Pass
20569	Pass	20570	Pass	20571	Pass	20572	Pass
20573	Pass	20574	Pass	20575	Pass	20576	Pass
20577	Pass	20578	Pass	20579	Pass	20580	Pass
20581	Pass	20582	Pass	20583	Pass	20584	Pass
20585	Pass	20586	Pass	20587	Pass	20588	Pass
20589	Pass	20590	Pass	20591	Pass	20592	Pass
20593	Pass	20594	Pass	20595	Pass	20596	Pass
20597	Pass	20598	Pass	20599	Pass	20600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory