

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/308/25	Model No.: KFARQ-6-50%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 308/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 30701 To 30800 And 30705A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 30705A and removed from the Lot/Batch							
30701	Pass	30702	Pass	30703	Pass	30704	Pass
30705	Pass	30706	Pass	30707	Pass	30708	Pass
30709	Pass	30710	Pass	30711	Pass	30712	Pass
30713	Pass	30714	Pass	30715	Pass	30716	Pass
30717	Pass	30718	Pass	30719	Pass	30720	Pass
30721	Pass	30722	Pass	30723	Pass	30724	Pass
30725	Pass	30726	Pass	30727	Pass	30728	Pass
30729	Pass	30730	Pass	30731	Pass	30732	Pass
30733	Pass	30734	Pass	30735	Pass	30736	Pass
30737	Pass	30738	Pass	30739	Pass	30740	Pass
30741	Pass	30742	Pass	30743	Pass	30744	Pass
30745	Pass	30746	Pass	30747	Pass	30748	Pass
30749	Pass	30750	Pass	30751	Pass	30752	Pass
30753	Pass	30754	Pass	30755	Pass	30756	Pass
30757	Pass	30758	Pass	30759	Pass	30760	Pass
30761	Pass	30762	Pass	30763	Pass	30764	Pass
30765	Pass	30766	Pass	30767	Pass	30768	Pass
30769	Pass	30770	Pass	30771	Pass	30772	Pass
30773	Pass	30774	Pass	30775	Pass	30776	Pass
30777	Pass	30778	Pass	30779	Pass	30780	Pass
30781	Pass	30782	Pass	30783	Pass	30784	Pass
30785	Pass	30786	Pass	30787	Pass	30788	Pass
30789	Pass	30790	Pass	30791	Pass	30792	Pass
30793	Pass	30794	Pass	30795	Pass	30796	Pass
30797	Pass	30798	Pass	30799	Pass	30800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory