

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/297/25	Model No.: MARQ-6-50%	Date: 22-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 297/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29601 To 29700 And 29605A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29605A and removed from the Lot/Batch							
29601	Pass	29602	Pass	29603	Pass	29604	Pass
29605	Pass	29606	Pass	29607	Pass	29608	Pass
29609	Pass	29610	Pass	29611	Pass	29612	Pass
29613	Pass	29614	Pass	29615	Pass	29616	Pass
29617	Pass	29618	Pass	29619	Pass	29620	Pass
29621	Pass	29622	Pass	29623	Pass	29624	Pass
29625	Pass	29626	Pass	29627	Pass	29628	Pass
29629	Pass	29630	Pass	29631	Pass	29632	Pass
29633	Pass	29634	Pass	29635	Pass	29636	Pass
29637	Pass	29638	Pass	29639	Pass	29640	Pass
29641	Pass	29642	Pass	29643	Pass	29644	Pass
29645	Pass	29646	Pass	29647	Pass	29648	Pass
29649	Pass	29650	Pass	29651	Pass	29652	Pass
29653	Pass	29654	Pass	29655	Pass	29656	Pass
29657	Pass	29658	Pass	29659	Pass	29660	Pass
29661	Pass	29662	Pass	29663	Pass	29664	Pass
29665	Pass	29666	Pass	29667	Pass	29668	Pass
29669	Pass	29670	Pass	29671	Pass	29672	Pass
29673	Pass	29674	Pass	29675	Pass	29676	Pass
29677	Pass	29678	Pass	29679	Pass	29680	Pass
29681	Pass	29682	Pass	29683	Pass	29684	Pass
29685	Pass	29686	Pass	29687	Pass	29688	Pass
29689	Pass	29690	Pass	29691	Pass	29692	Pass
29693	Pass	29694	Pass	29695	Pass	29696	Pass
29697	Pass	29698	Pass	29699	Pass	29700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory