

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/243/25	Model No.: KFARQ-6-90%	Date: 07-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 243/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24201 To 24300 And 24205A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24205A and removed from the Lot/Batch							
24201	Pass	24202	Pass	24203	Pass	24204	Pass
24205	Pass	24206	Pass	24207	Pass	24208	Pass
24209	Pass	24210	Pass	24211	Pass	24212	Pass
24213	Pass	24214	Pass	24215	Pass	24216	Pass
24217	Pass	24218	Pass	24219	Pass	24220	Pass
24221	Pass	24222	Pass	24223	Pass	24224	Pass
24225	Pass	24226	Pass	24227	Pass	24228	Pass
24229	Pass	24230	Pass	24231	Pass	24232	Pass
24233	Pass	24234	Pass	24235	Pass	24236	Pass
24237	Pass	24238	Pass	24239	Pass	24240	Pass
24241	Pass	24242	Pass	24243	Pass	24244	Pass
24245	Pass	24246	Pass	24247	Pass	24248	Pass
24249	Pass	24250	Pass	24251	Pass	24252	Pass
24253	Pass	24254	Pass	24255	Pass	24256	Pass
24257	Pass	24258	Pass	24259	Pass	24260	Pass
24261	Pass	24262	Pass	24263	Pass	24264	Pass
24265	Pass	24266	Pass	24267	Pass	24268	Pass
24269	Pass	24270	Pass	24271	Pass	24272	Pass
24273	Pass	24274	Pass	24275	Pass	24276	Pass
24277	Pass	24278	Pass	24279	Pass	24280	Pass
24281	Pass	24282	Pass	24283	Pass	24284	Pass
24285	Pass	24286	Pass	24287	Pass	24288	Pass
24289	Pass	24290	Pass	24291	Pass	24292	Pass
24293	Pass	24294	Pass	24295	Pass	24296	Pass
24297	Pass	24298	Pass	24299	Pass	24300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory