

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/114/25	Model No.: MARQ-6-50%	Date: 12-04-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 114/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11301 To 11400 And 11305A	
Month of Manufacturing	: Apr/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11305A and removed from the Lot/Batch							
11301	Pass	11302	Pass	11303	Pass	11304	Pass
11305	Pass	11306	Pass	11307	Pass	11308	Pass
11309	Pass	11310	Pass	11311	Pass	11312	Pass
11313	Pass	11314	Pass	11315	Pass	11316	Pass
11317	Pass	11318	Pass	11319	Pass	11320	Pass
11321	Pass	11322	Pass	11323	Pass	11324	Pass
11325	Pass	11326	Pass	11327	Pass	11328	Pass
11329	Pass	11330	Pass	11331	Pass	11332	Pass
11333	Pass	11334	Pass	11335	Pass	11336	Pass
11337	Pass	11338	Pass	11339	Pass	11340	Pass
11341	Pass	11342	Pass	11343	Pass	11344	Pass
11345	Pass	11346	Pass	11347	Pass	11348	Pass
11349	Pass	11350	Pass	11351	Pass	11352	Pass
11353	Pass	11354	Pass	11355	Pass	11356	Pass
11357	Pass	11358	Pass	11359	Pass	11360	Pass
11361	Pass	11362	Pass	11363	Pass	11364	Pass
11365	Pass	11366	Pass	11367	Pass	11368	Pass
11369	Pass	11370	Pass	11371	Pass	11372	Pass
11373	Pass	11374	Pass	11375	Pass	11376	Pass
11377	Pass	11378	Pass	11379	Pass	11380	Pass
11381	Pass	11382	Pass	11383	Pass	11384	Pass
11385	Pass	11386	Pass	11387	Pass	11388	Pass
11389	Pass	11390	Pass	11391	Pass	11392	Pass
11393	Pass	11394	Pass	11395	Pass	11396	Pass
11397	Pass	11398	Pass	11399	Pass	11400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory