

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/264/25	Model No.: KFARQ-6-50%	Date: 18-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 264/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26301 To 26400 And 26305A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26305A and removed from the Lot/Batch							
26301	Pass	26302	Pass	26303	Pass	26304	Pass
26305	Pass	26306	Pass	26307	Pass	26308	Pass
26309	Pass	26310	Pass	26311	Pass	26312	Pass
26313	Pass	26314	Pass	26315	Pass	26316	Pass
26317	Pass	26318	Pass	26319	Pass	26320	Pass
26321	Pass	26322	Pass	26323	Pass	26324	Pass
26325	Pass	26326	Pass	26327	Pass	26328	Pass
26329	Pass	26330	Pass	26331	Pass	26332	Pass
26333	Pass	26334	Pass	26335	Pass	26336	Pass
26337	Pass	26338	Pass	26339	Pass	26340	Pass
26341	Pass	26342	Pass	26343	Pass	26344	Pass
26345	Pass	26346	Pass	26347	Pass	26348	Pass
26349	Pass	26350	Pass	26351	Pass	26352	Pass
26353	Pass	26354	Pass	26355	Pass	26356	Pass
26357	Pass	26358	Pass	26359	Pass	26360	Pass
26361	Pass	26362	Pass	26363	Pass	26364	Pass
26365	Pass	26366	Pass	26367	Pass	26368	Pass
26369	Pass	26370	Pass	26371	Pass	26372	Pass
26373	Pass	26374	Pass	26375	Pass	26376	Pass
26377	Pass	26378	Pass	26379	Pass	26380	Pass
26381	Pass	26382	Pass	26383	Pass	26384	Pass
26385	Pass	26386	Pass	26387	Pass	26388	Pass
26389	Pass	26390	Pass	26391	Pass	26392	Pass
26393	Pass	26394	Pass	26395	Pass	26396	Pass
26397	Pass	26398	Pass	26399	Pass	26400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory