

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/279/25	Model No.: KFARQ-6-50%	Date: 24-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 279/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27801 To 27900 And 27805A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27805A and removed from the Lot/Batch							
27801	Pass	27802	Pass	27803	Pass	27804	Pass
27805	Pass	27806	Pass	27807	Pass	27808	Pass
27809	Pass	27810	Pass	27811	Pass	27812	Pass
27813	Pass	27814	Pass	27815	Pass	27816	Pass
27817	Pass	27818	Pass	27819	Pass	27820	Pass
27821	Pass	27822	Pass	27823	Pass	27824	Pass
27825	Pass	27826	Pass	27827	Pass	27828	Pass
27829	Pass	27830	Pass	27831	Pass	27832	Pass
27833	Pass	27834	Pass	27835	Pass	27836	Pass
27837	Pass	27838	Pass	27839	Pass	27840	Pass
27841	Pass	27842	Pass	27843	Pass	27844	Pass
27845	Pass	27846	Pass	27847	Pass	27848	Pass
27849	Pass	27850	Pass	27851	Pass	27852	Pass
27853	Pass	27854	Pass	27855	Pass	27856	Pass
27857	Pass	27858	Pass	27859	Pass	27860	Pass
27861	Pass	27862	Pass	27863	Pass	27864	Pass
27865	Pass	27866	Pass	27867	Pass	27868	Pass
27869	Pass	27870	Pass	27871	Pass	27872	Pass
27873	Pass	27874	Pass	27875	Pass	27876	Pass
27877	Pass	27878	Pass	27879	Pass	27880	Pass
27881	Pass	27882	Pass	27883	Pass	27884	Pass
27885	Pass	27886	Pass	27887	Pass	27888	Pass
27889	Pass	27890	Pass	27891	Pass	27892	Pass
27893	Pass	27894	Pass	27895	Pass	27896	Pass
27897	Pass	27898	Pass	27899	Pass	27900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory