

# HYDRO PRESSURE TEST

|                                   |                                                         |                  |
|-----------------------------------|---------------------------------------------------------|------------------|
| TC No.: HPT/W9/SP/RQ/038/25       | Model No.: KFWSRQ-9                                     | Date: 23-09-2025 |
| Type and Capacity of Extinguisher | : KFWSRQ-9-Kanex Water SP Fire Extinguisher Cap. 9 Ltr. |                  |
| Batch Number                      | : KFWSRQ9 038/25                                        |                  |
| Batch Quantity                    | : 101.00 Nos.                                           |                  |
| Serial Numbers                    | : 03701 To 3800 And 3705A                               |                  |
| Month of Manufacturing            | : Sep/25                                                |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 3705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 3701                                                         | Pass   | 3702     | Pass   | 3703     | Pass   | 3704     | Pass   |
| 3705                                                         | Pass   | 3706     | Pass   | 3707     | Pass   | 3708     | Pass   |
| 3709                                                         | Pass   | 3710     | Pass   | 3711     | Pass   | 3712     | Pass   |
| 3713                                                         | Pass   | 3714     | Pass   | 3715     | Pass   | 3716     | Pass   |
| 3717                                                         | Pass   | 3718     | Pass   | 3719     | Pass   | 3720     | Pass   |
| 3721                                                         | Pass   | 3722     | Pass   | 3723     | Pass   | 3724     | Pass   |
| 3725                                                         | Pass   | 3726     | Pass   | 3727     | Pass   | 3728     | Pass   |
| 3729                                                         | Pass   | 3730     | Pass   | 3731     | Pass   | 3732     | Pass   |
| 3733                                                         | Pass   | 3734     | Pass   | 3735     | Pass   | 3736     | Pass   |
| 3737                                                         | Pass   | 3738     | Pass   | 3739     | Pass   | 3740     | Pass   |
| 3741                                                         | Pass   | 3742     | Pass   | 3743     | Pass   | 3744     | Pass   |
| 3745                                                         | Pass   | 3746     | Pass   | 3747     | Pass   | 3748     | Pass   |
| 3749                                                         | Pass   | 3750     | Pass   | 3751     | Pass   | 3752     | Pass   |
| 3753                                                         | Pass   | 3754     | Pass   | 3755     | Pass   | 3756     | Pass   |
| 3757                                                         | Pass   | 3758     | Pass   | 3759     | Pass   | 3760     | Pass   |
| 3761                                                         | Pass   | 3762     | Pass   | 3763     | Pass   | 3764     | Pass   |
| 3765                                                         | Pass   | 3766     | Pass   | 3767     | Pass   | 3768     | Pass   |
| 3769                                                         | Pass   | 3770     | Pass   | 3771     | Pass   | 3772     | Pass   |
| 3773                                                         | Pass   | 3774     | Pass   | 3775     | Pass   | 3776     | Pass   |
| 3777                                                         | Pass   | 3778     | Pass   | 3779     | Pass   | 3780     | Pass   |
| 3781                                                         | Pass   | 3782     | Pass   | 3783     | Pass   | 3784     | Pass   |
| 3785                                                         | Pass   | 3786     | Pass   | 3787     | Pass   | 3788     | Pass   |
| 3789                                                         | Pass   | 3790     | Pass   | 3791     | Pass   | 3792     | Pass   |
| 3793                                                         | Pass   | 3794     | Pass   | 3795     | Pass   | 3796     | Pass   |
| 3797                                                         | Pass   | 3798     | Pass   | 3799     | Pass   | 3800     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**