

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/342/25	Model No.: MARQ-6-50%	Date: 04-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 342/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 34101 To 34200 And 34105A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 34105A and removed from the Lot/Batch							
34101	Pass	34102	Pass	34103	Pass	34104	Pass
34105	Pass	34106	Pass	34107	Pass	34108	Pass
34109	Pass	34110	Pass	34111	Pass	34112	Pass
34113	Pass	34114	Pass	34115	Pass	34116	Pass
34117	Pass	34118	Pass	34119	Pass	34120	Pass
34121	Pass	34122	Pass	34123	Pass	34124	Pass
34125	Pass	34126	Pass	34127	Pass	34128	Pass
34129	Pass	34130	Pass	34131	Pass	34132	Pass
34133	Pass	34134	Pass	34135	Pass	34136	Pass
34137	Pass	34138	Pass	34139	Pass	34140	Pass
34141	Pass	34142	Pass	34143	Pass	34144	Pass
34145	Pass	34146	Pass	34147	Pass	34148	Pass
34149	Pass	34150	Pass	34151	Pass	34152	Pass
34153	Pass	34154	Pass	34155	Pass	34156	Pass
34157	Pass	34158	Pass	34159	Pass	34160	Pass
34161	Pass	34162	Pass	34163	Pass	34164	Pass
34165	Pass	34166	Pass	34167	Pass	34168	Pass
34169	Pass	34170	Pass	34171	Pass	34172	Pass
34173	Pass	34174	Pass	34175	Pass	34176	Pass
34177	Pass	34178	Pass	34179	Pass	34180	Pass
34181	Pass	34182	Pass	34183	Pass	34184	Pass
34185	Pass	34186	Pass	34187	Pass	34188	Pass
34189	Pass	34190	Pass	34191	Pass	34192	Pass
34193	Pass	34194	Pass	34195	Pass	34196	Pass
34197	Pass	34198	Pass	34199	Pass	34200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory