

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/343/25	Model No.: MARQ-6-50%	Date: 04-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 343/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 34201 To 34300 And 34205A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 34205A and removed from the Lot/Batch							
34201	Pass	34202	Pass	34203	Pass	34204	Pass
34205	Pass	34206	Pass	34207	Pass	34208	Pass
34209	Pass	34210	Pass	34211	Pass	34212	Pass
34213	Pass	34214	Pass	34215	Pass	34216	Pass
34217	Pass	34218	Pass	34219	Pass	34220	Pass
34221	Pass	34222	Pass	34223	Pass	34224	Pass
34225	Pass	34226	Pass	34227	Pass	34228	Pass
34229	Pass	34230	Pass	34231	Pass	34232	Pass
34233	Pass	34234	Pass	34235	Pass	34236	Pass
34237	Pass	34238	Pass	34239	Pass	34240	Pass
34241	Pass	34242	Pass	34243	Pass	34244	Pass
34245	Pass	34246	Pass	34247	Pass	34248	Pass
34249	Pass	34250	Pass	34251	Pass	34252	Pass
34253	Pass	34254	Pass	34255	Pass	34256	Pass
34257	Pass	34258	Pass	34259	Pass	34260	Pass
34261	Pass	34262	Pass	34263	Pass	34264	Pass
34265	Pass	34266	Pass	34267	Pass	34268	Pass
34269	Pass	34270	Pass	34271	Pass	34272	Pass
34273	Pass	34274	Pass	34275	Pass	34276	Pass
34277	Pass	34278	Pass	34279	Pass	34280	Pass
34281	Pass	34282	Pass	34283	Pass	34284	Pass
34285	Pass	34286	Pass	34287	Pass	34288	Pass
34289	Pass	34290	Pass	34291	Pass	34292	Pass
34293	Pass	34294	Pass	34295	Pass	34296	Pass
34297	Pass	34298	Pass	34299	Pass	34300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory