

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A90/RQ/017/25	Model No.: MARQ-6-90%	Date: 09-05-2025
Type and Capacity of Extinguisher	: MARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ90%6 017/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01601 To 1700 And 1605A	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1605A and removed from the Lot/Batch							
1601	Pass	1602	Pass	1603	Pass	1604	Pass
1605	Pass	1606	Pass	1607	Pass	1608	Pass
1609	Pass	1610	Pass	1611	Pass	1612	Pass
1613	Pass	1614	Pass	1615	Pass	1616	Pass
1617	Pass	1618	Pass	1619	Pass	1620	Pass
1621	Pass	1622	Pass	1623	Pass	1624	Pass
1625	Pass	1626	Pass	1627	Pass	1628	Pass
1629	Pass	1630	Pass	1631	Pass	1632	Pass
1633	Pass	1634	Pass	1635	Pass	1636	Pass
1637	Pass	1638	Pass	1639	Pass	1640	Pass
1641	Pass	1642	Pass	1643	Pass	1644	Pass
1645	Pass	1646	Pass	1647	Pass	1648	Pass
1649	Pass	1650	Pass	1651	Pass	1652	Pass
1653	Pass	1654	Pass	1655	Pass	1656	Pass
1657	Pass	1658	Pass	1659	Pass	1660	Pass
1661	Pass	1662	Pass	1663	Pass	1664	Pass
1665	Pass	1666	Pass	1667	Pass	1668	Pass
1669	Pass	1670	Pass	1671	Pass	1672	Pass
1673	Pass	1674	Pass	1675	Pass	1676	Pass
1677	Pass	1678	Pass	1679	Pass	1680	Pass
1681	Pass	1682	Pass	1683	Pass	1684	Pass
1685	Pass	1686	Pass	1687	Pass	1688	Pass
1689	Pass	1690	Pass	1691	Pass	1692	Pass
1693	Pass	1694	Pass	1695	Pass	1696	Pass
1697	Pass	1698	Pass	1699	Pass	1700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory