

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/256/25	Model No.: KFARQ-6-50%	Date: 26-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 256/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25501 To 25600 And 25505A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25505A and removed from the Lot/Batch							
25501	Pass	25502	Pass	25503	Pass	25504	Pass
25505	Pass	25506	Pass	25507	Pass	25508	Pass
25509	Pass	25510	Pass	25511	Pass	25512	Pass
25513	Pass	25514	Pass	25515	Pass	25516	Pass
25517	Pass	25518	Pass	25519	Pass	25520	Pass
25521	Pass	25522	Pass	25523	Pass	25524	Pass
25525	Pass	25526	Pass	25527	Pass	25528	Pass
25529	Pass	25530	Pass	25531	Pass	25532	Pass
25533	Pass	25534	Pass	25535	Pass	25536	Pass
25537	Pass	25538	Pass	25539	Pass	25540	Pass
25541	Pass	25542	Pass	25543	Pass	25544	Pass
25545	Pass	25546	Pass	25547	Pass	25548	Pass
25549	Pass	25550	Pass	25551	Pass	25552	Pass
25553	Pass	25554	Pass	25555	Pass	25556	Pass
25557	Pass	25558	Pass	25559	Pass	25560	Pass
25561	Pass	25562	Pass	25563	Pass	25564	Pass
25565	Pass	25566	Pass	25567	Pass	25568	Pass
25569	Pass	25570	Pass	25571	Pass	25572	Pass
25573	Pass	25574	Pass	25575	Pass	25576	Pass
25577	Pass	25578	Pass	25579	Pass	25580	Pass
25581	Pass	25582	Pass	25583	Pass	25584	Pass
25585	Pass	25586	Pass	25587	Pass	25588	Pass
25589	Pass	25590	Pass	25591	Pass	25592	Pass
25593	Pass	25594	Pass	25595	Pass	25596	Pass
25597	Pass	25598	Pass	25599	Pass	25600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory