

HYDRO PRESSURE TEST

TC No.: HPT/A6/A40/RQ/010/25	Model No.: KFARQ-6-40%	Date: 05-04-2025
Type and Capacity of Extinguisher	: KFARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ40%6 010/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00901 To 1000 And 905A	
Month of Manufacturing	: Apr/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 905A and removed from the Lot/Batch							
901	Pass	902	Pass	903	Pass	904	Pass
905	Pass	906	Pass	907	Pass	908	Pass
909	Pass	910	Pass	911	Pass	912	Pass
913	Pass	914	Pass	915	Pass	916	Pass
917	Pass	918	Pass	919	Pass	920	Pass
921	Pass	922	Pass	923	Pass	924	Pass
925	Pass	926	Pass	927	Pass	928	Pass
929	Pass	930	Pass	931	Pass	932	Pass
933	Pass	934	Pass	935	Pass	936	Pass
937	Pass	938	Pass	939	Pass	940	Pass
941	Pass	942	Pass	943	Pass	944	Pass
945	Pass	946	Pass	947	Pass	948	Pass
949	Pass	950	Pass	951	Pass	952	Pass
953	Pass	954	Pass	955	Pass	956	Pass
957	Pass	958	Pass	959	Pass	960	Pass
961	Pass	962	Pass	963	Pass	964	Pass
965	Pass	966	Pass	967	Pass	968	Pass
969	Pass	970	Pass	971	Pass	972	Pass
973	Pass	974	Pass	975	Pass	976	Pass
977	Pass	978	Pass	979	Pass	980	Pass
981	Pass	982	Pass	983	Pass	984	Pass
985	Pass	986	Pass	987	Pass	988	Pass
989	Pass	990	Pass	991	Pass	992	Pass
993	Pass	994	Pass	995	Pass	996	Pass
997	Pass	998	Pass	999	Pass	1000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory