

HYDRO PRESSURE TEST

TC No.: HPT/A2/K/HQ/012/25	Model No.: KFKHQ-2	Date: 03-07-2025
Type and Capacity of Extinguisher	: KFKHQ-2-Kanex F Class Kitchen Fire Extinguisher Cap. 2 Ltr.	
Batch Number	: KFKHQ2 012/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00111 To 120	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00111 To 120 and removed from the Lot/Batch							
111	Pass	112	Pass	113	Pass	114	Pass
115	Pass	116	Pass	117	Pass	118	Pass
119	Pass	120	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory