

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/341/25	Model No.: MARQ-6-50%	Date: 04-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 341/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 34001 To 34100 And 34005A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 34005A and removed from the Lot/Batch							
34001	Pass	34002	Pass	34003	Pass	34004	Pass
34005	Pass	34006	Pass	34007	Pass	34008	Pass
34009	Pass	34010	Pass	34011	Pass	34012	Pass
34013	Pass	34014	Pass	34015	Pass	34016	Pass
34017	Pass	34018	Pass	34019	Pass	34020	Pass
34021	Pass	34022	Pass	34023	Pass	34024	Pass
34025	Pass	34026	Pass	34027	Pass	34028	Pass
34029	Pass	34030	Pass	34031	Pass	34032	Pass
34033	Pass	34034	Pass	34035	Pass	34036	Pass
34037	Pass	34038	Pass	34039	Pass	34040	Pass
34041	Pass	34042	Pass	34043	Pass	34044	Pass
34045	Pass	34046	Pass	34047	Pass	34048	Pass
34049	Pass	34050	Pass	34051	Pass	34052	Pass
34053	Pass	34054	Pass	34055	Pass	34056	Pass
34057	Pass	34058	Pass	34059	Pass	34060	Pass
34061	Pass	34062	Pass	34063	Pass	34064	Pass
34065	Pass	34066	Pass	34067	Pass	34068	Pass
34069	Pass	34070	Pass	34071	Pass	34072	Pass
34073	Pass	34074	Pass	34075	Pass	34076	Pass
34077	Pass	34078	Pass	34079	Pass	34080	Pass
34081	Pass	34082	Pass	34083	Pass	34084	Pass
34085	Pass	34086	Pass	34087	Pass	34088	Pass
34089	Pass	34090	Pass	34091	Pass	34092	Pass
34093	Pass	34094	Pass	34095	Pass	34096	Pass
34097	Pass	34098	Pass	34099	Pass	34100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory