

# HYDRO PRESSURE TEST

|                                   |                                                                       |                  |
|-----------------------------------|-----------------------------------------------------------------------|------------------|
| TC No.: HPT/W45/RQ/016/25         | Model No.: KFWRQ-45                                                   | Date: 18-11-2025 |
| Type and Capacity of Extinguisher | : KFWRQ-45-Kanex Water Trolley Mounted Fire Extinguisher Cap. 45 Ltr. |                  |
| Batch Number                      | : KFWRQ45 016/25                                                      |                  |
| Batch Quantity                    | : 6.00 Nos.                                                           |                  |
| Serial Numbers                    | : 00076 To 80 And 80A                                                 |                  |
| Month of Manufacturing            | : Nov/25                                                              |                  |

| Sr. Nos.                                                   | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 80A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 76                                                         | Pass   | 77       | Pass   | 78       | Pass   | 79       | Pass   |
| 80                                                         | Pass   |          |        |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



**Authorized Signatory**