

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/344/25	Model No.: MARQ-6-50%	Date: 04-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 344/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 34301 To 34400 And 34305A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 34305A and removed from the Lot/Batch							
34301	Pass	34302	Pass	34303	Pass	34304	Pass
34305	Pass	34306	Pass	34307	Pass	34308	Pass
34309	Pass	34310	Pass	34311	Pass	34312	Pass
34313	Pass	34314	Pass	34315	Pass	34316	Pass
34317	Pass	34318	Pass	34319	Pass	34320	Pass
34321	Pass	34322	Pass	34323	Pass	34324	Pass
34325	Pass	34326	Pass	34327	Pass	34328	Pass
34329	Pass	34330	Pass	34331	Pass	34332	Pass
34333	Pass	34334	Pass	34335	Pass	34336	Pass
34337	Pass	34338	Pass	34339	Pass	34340	Pass
34341	Pass	34342	Pass	34343	Pass	34344	Pass
34345	Pass	34346	Pass	34347	Pass	34348	Pass
34349	Pass	34350	Pass	34351	Pass	34352	Pass
34353	Pass	34354	Pass	34355	Pass	34356	Pass
34357	Pass	34358	Pass	34359	Pass	34360	Pass
34361	Pass	34362	Pass	34363	Pass	34364	Pass
34365	Pass	34366	Pass	34367	Pass	34368	Pass
34369	Pass	34370	Pass	34371	Pass	34372	Pass
34373	Pass	34374	Pass	34375	Pass	34376	Pass
34377	Pass	34378	Pass	34379	Pass	34380	Pass
34381	Pass	34382	Pass	34383	Pass	34384	Pass
34385	Pass	34386	Pass	34387	Pass	34388	Pass
34389	Pass	34390	Pass	34391	Pass	34392	Pass
34393	Pass	34394	Pass	34395	Pass	34396	Pass
34397	Pass	34398	Pass	34399	Pass	34400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory