

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/339/25	Model No.: MARQ-6-50%	Date: 02-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 339/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 33801 To 33900 And 33805A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 33805A and removed from the Lot/Batch							
33801	Pass	33802	Pass	33803	Pass	33804	Pass
33805	Pass	33806	Pass	33807	Pass	33808	Pass
33809	Pass	33810	Pass	33811	Pass	33812	Pass
33813	Pass	33814	Pass	33815	Pass	33816	Pass
33817	Pass	33818	Pass	33819	Pass	33820	Pass
33821	Pass	33822	Pass	33823	Pass	33824	Pass
33825	Pass	33826	Pass	33827	Pass	33828	Pass
33829	Pass	33830	Pass	33831	Pass	33832	Pass
33833	Pass	33834	Pass	33835	Pass	33836	Pass
33837	Pass	33838	Pass	33839	Pass	33840	Pass
33841	Pass	33842	Pass	33843	Pass	33844	Pass
33845	Pass	33846	Pass	33847	Pass	33848	Pass
33849	Pass	33850	Pass	33851	Pass	33852	Pass
33853	Pass	33854	Pass	33855	Pass	33856	Pass
33857	Pass	33858	Pass	33859	Pass	33860	Pass
33861	Pass	33862	Pass	33863	Pass	33864	Pass
33865	Pass	33866	Pass	33867	Pass	33868	Pass
33869	Pass	33870	Pass	33871	Pass	33872	Pass
33873	Pass	33874	Pass	33875	Pass	33876	Pass
33877	Pass	33878	Pass	33879	Pass	33880	Pass
33881	Pass	33882	Pass	33883	Pass	33884	Pass
33885	Pass	33886	Pass	33887	Pass	33888	Pass
33889	Pass	33890	Pass	33891	Pass	33892	Pass
33893	Pass	33894	Pass	33895	Pass	33896	Pass
33897	Pass	33898	Pass	33899	Pass	33900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory