

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/241/25	Model No.: KFARQ-6-90%	Date: 04-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 241/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24001 To 24100 And 24005A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24005A and removed from the Lot/Batch							
24001	Pass	24002	Pass	24003	Pass	24004	Pass
24005	Pass	24006	Pass	24007	Pass	24008	Pass
24009	Pass	24010	Pass	24011	Pass	24012	Pass
24013	Pass	24014	Pass	24015	Pass	24016	Pass
24017	Pass	24018	Pass	24019	Pass	24020	Pass
24021	Pass	24022	Pass	24023	Pass	24024	Pass
24025	Pass	24026	Pass	24027	Pass	24028	Pass
24029	Pass	24030	Pass	24031	Pass	24032	Pass
24033	Pass	24034	Pass	24035	Pass	24036	Pass
24037	Pass	24038	Pass	24039	Pass	24040	Pass
24041	Pass	24042	Pass	24043	Pass	24044	Pass
24045	Pass	24046	Pass	24047	Pass	24048	Pass
24049	Pass	24050	Pass	24051	Pass	24052	Pass
24053	Pass	24054	Pass	24055	Pass	24056	Pass
24057	Pass	24058	Pass	24059	Pass	24060	Pass
24061	Pass	24062	Pass	24063	Pass	24064	Pass
24065	Pass	24066	Pass	24067	Pass	24068	Pass
24069	Pass	24070	Pass	24071	Pass	24072	Pass
24073	Pass	24074	Pass	24075	Pass	24076	Pass
24077	Pass	24078	Pass	24079	Pass	24080	Pass
24081	Pass	24082	Pass	24083	Pass	24084	Pass
24085	Pass	24086	Pass	24087	Pass	24088	Pass
24089	Pass	24090	Pass	24091	Pass	24092	Pass
24093	Pass	24094	Pass	24095	Pass	24096	Pass
24097	Pass	24098	Pass	24099	Pass	24100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory