

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/358/25	Model No.: MARQ-6-50%	Date: 12-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 358/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35701 To 35800 And 35705A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35705A and removed from the Lot/Batch							
35701	Pass	35702	Pass	35703	Pass	35704	Pass
35705	Pass	35706	Pass	35707	Pass	35708	Pass
35709	Pass	35710	Pass	35711	Pass	35712	Pass
35713	Pass	35714	Pass	35715	Pass	35716	Pass
35717	Pass	35718	Pass	35719	Pass	35720	Pass
35721	Pass	35722	Pass	35723	Pass	35724	Pass
35725	Pass	35726	Pass	35727	Pass	35728	Pass
35729	Pass	35730	Pass	35731	Pass	35732	Pass
35733	Pass	35734	Pass	35735	Pass	35736	Pass
35737	Pass	35738	Pass	35739	Pass	35740	Pass
35741	Pass	35742	Pass	35743	Pass	35744	Pass
35745	Pass	35746	Pass	35747	Pass	35748	Pass
35749	Pass	35750	Pass	35751	Pass	35752	Pass
35753	Pass	35754	Pass	35755	Pass	35756	Pass
35757	Pass	35758	Pass	35759	Pass	35760	Pass
35761	Pass	35762	Pass	35763	Pass	35764	Pass
35765	Pass	35766	Pass	35767	Pass	35768	Pass
35769	Pass	35770	Pass	35771	Pass	35772	Pass
35773	Pass	35774	Pass	35775	Pass	35776	Pass
35777	Pass	35778	Pass	35779	Pass	35780	Pass
35781	Pass	35782	Pass	35783	Pass	35784	Pass
35785	Pass	35786	Pass	35787	Pass	35788	Pass
35789	Pass	35790	Pass	35791	Pass	35792	Pass
35793	Pass	35794	Pass	35795	Pass	35796	Pass
35797	Pass	35798	Pass	35799	Pass	35800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory