

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/220/25	Model No.: MARQ-6-40%	Date: 15-12-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 220/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21901 To 22000 And 21905A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21905A and removed from the Lot/Batch							
21901	Pass	21902	Pass	21903	Pass	21904	Pass
21905	Pass	21906	Pass	21907	Pass	21908	Pass
21909	Pass	21910	Pass	21911	Pass	21912	Pass
21913	Pass	21914	Pass	21915	Pass	21916	Pass
21917	Pass	21918	Pass	21919	Pass	21920	Pass
21921	Pass	21922	Pass	21923	Pass	21924	Pass
21925	Pass	21926	Pass	21927	Pass	21928	Pass
21929	Pass	21930	Pass	21931	Pass	21932	Pass
21933	Pass	21934	Pass	21935	Pass	21936	Pass
21937	Pass	21938	Pass	21939	Pass	21940	Pass
21941	Pass	21942	Pass	21943	Pass	21944	Pass
21945	Pass	21946	Pass	21947	Pass	21948	Pass
21949	Pass	21950	Pass	21951	Pass	21952	Pass
21953	Pass	21954	Pass	21955	Pass	21956	Pass
21957	Pass	21958	Pass	21959	Pass	21960	Pass
21961	Pass	21962	Pass	21963	Pass	21964	Pass
21965	Pass	21966	Pass	21967	Pass	21968	Pass
21969	Pass	21970	Pass	21971	Pass	21972	Pass
21973	Pass	21974	Pass	21975	Pass	21976	Pass
21977	Pass	21978	Pass	21979	Pass	21980	Pass
21981	Pass	21982	Pass	21983	Pass	21984	Pass
21985	Pass	21986	Pass	21987	Pass	21988	Pass
21989	Pass	21990	Pass	21991	Pass	21992	Pass
21993	Pass	21994	Pass	21995	Pass	21996	Pass
21997	Pass	21998	Pass	21999	Pass	22000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 A circular purple stamp with the text "SIHOR (GUJARAT)" in the center and "KANEX FIRE SOLUTIONS LIMITED" around the perimeter. A signature is written over the stamp.

Authorized Signatory