

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/199/25	Model No.: KFARQ-4-90%	Date: 24-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 199/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19801 To 19900 And 19805A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19805A and removed from the Lot/Batch							
19801	Pass	19802	Pass	19803	Pass	19804	Pass
19805	Pass	19806	Pass	19807	Pass	19808	Pass
19809	Pass	19810	Pass	19811	Pass	19812	Pass
19813	Pass	19814	Pass	19815	Pass	19816	Pass
19817	Pass	19818	Pass	19819	Pass	19820	Pass
19821	Pass	19822	Pass	19823	Pass	19824	Pass
19825	Pass	19826	Pass	19827	Pass	19828	Pass
19829	Pass	19830	Pass	19831	Pass	19832	Pass
19833	Pass	19834	Pass	19835	Pass	19836	Pass
19837	Pass	19838	Pass	19839	Pass	19840	Pass
19841	Pass	19842	Pass	19843	Pass	19844	Pass
19845	Pass	19846	Pass	19847	Pass	19848	Pass
19849	Pass	19850	Pass	19851	Pass	19852	Pass
19853	Pass	19854	Pass	19855	Pass	19856	Pass
19857	Pass	19858	Pass	19859	Pass	19860	Pass
19861	Pass	19862	Pass	19863	Pass	19864	Pass
19865	Pass	19866	Pass	19867	Pass	19868	Pass
19869	Pass	19870	Pass	19871	Pass	19872	Pass
19873	Pass	19874	Pass	19875	Pass	19876	Pass
19877	Pass	19878	Pass	19879	Pass	19880	Pass
19881	Pass	19882	Pass	19883	Pass	19884	Pass
19885	Pass	19886	Pass	19887	Pass	19888	Pass
19889	Pass	19890	Pass	19891	Pass	19892	Pass
19893	Pass	19894	Pass	19895	Pass	19896	Pass
19897	Pass	19898	Pass	19899	Pass	19900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory