

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/359/25	Model No.: MARQ-6-50%	Date: 12-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 359/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35801 To 35900 And 35805A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35805A and removed from the Lot/Batch							
35801	Pass	35802	Pass	35803	Pass	35804	Pass
35805	Pass	35806	Pass	35807	Pass	35808	Pass
35809	Pass	35810	Pass	35811	Pass	35812	Pass
35813	Pass	35814	Pass	35815	Pass	35816	Pass
35817	Pass	35818	Pass	35819	Pass	35820	Pass
35821	Pass	35822	Pass	35823	Pass	35824	Pass
35825	Pass	35826	Pass	35827	Pass	35828	Pass
35829	Pass	35830	Pass	35831	Pass	35832	Pass
35833	Pass	35834	Pass	35835	Pass	35836	Pass
35837	Pass	35838	Pass	35839	Pass	35840	Pass
35841	Pass	35842	Pass	35843	Pass	35844	Pass
35845	Pass	35846	Pass	35847	Pass	35848	Pass
35849	Pass	35850	Pass	35851	Pass	35852	Pass
35853	Pass	35854	Pass	35855	Pass	35856	Pass
35857	Pass	35858	Pass	35859	Pass	35860	Pass
35861	Pass	35862	Pass	35863	Pass	35864	Pass
35865	Pass	35866	Pass	35867	Pass	35868	Pass
35869	Pass	35870	Pass	35871	Pass	35872	Pass
35873	Pass	35874	Pass	35875	Pass	35876	Pass
35877	Pass	35878	Pass	35879	Pass	35880	Pass
35881	Pass	35882	Pass	35883	Pass	35884	Pass
35885	Pass	35886	Pass	35887	Pass	35888	Pass
35889	Pass	35890	Pass	35891	Pass	35892	Pass
35893	Pass	35894	Pass	35895	Pass	35896	Pass
35897	Pass	35898	Pass	35899	Pass	35900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory