

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/346/25	Model No.: KFARQ-6-50%	Date: 12-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 346/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 34501 To 34600 And 34505A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 34505A and removed from the Lot/Batch							
34501	Pass	34502	Pass	34503	Pass	34504	Pass
34505	Pass	34506	Pass	34507	Pass	34508	Pass
34509	Pass	34510	Pass	34511	Pass	34512	Pass
34513	Pass	34514	Pass	34515	Pass	34516	Pass
34517	Pass	34518	Pass	34519	Pass	34520	Pass
34521	Pass	34522	Pass	34523	Pass	34524	Pass
34525	Pass	34526	Pass	34527	Pass	34528	Pass
34529	Pass	34530	Pass	34531	Pass	34532	Pass
34533	Pass	34534	Pass	34535	Pass	34536	Pass
34537	Pass	34538	Pass	34539	Pass	34540	Pass
34541	Pass	34542	Pass	34543	Pass	34544	Pass
34545	Pass	34546	Pass	34547	Pass	34548	Pass
34549	Pass	34550	Pass	34551	Pass	34552	Pass
34553	Pass	34554	Pass	34555	Pass	34556	Pass
34557	Pass	34558	Pass	34559	Pass	34560	Pass
34561	Pass	34562	Pass	34563	Pass	34564	Pass
34565	Pass	34566	Pass	34567	Pass	34568	Pass
34569	Pass	34570	Pass	34571	Pass	34572	Pass
34573	Pass	34574	Pass	34575	Pass	34576	Pass
34577	Pass	34578	Pass	34579	Pass	34580	Pass
34581	Pass	34582	Pass	34583	Pass	34584	Pass
34585	Pass	34586	Pass	34587	Pass	34588	Pass
34589	Pass	34590	Pass	34591	Pass	34592	Pass
34593	Pass	34594	Pass	34595	Pass	34596	Pass
34597	Pass	34598	Pass	34599	Pass	34600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory