

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/356/25	Model No.: MARQ-6-50%	Date: 12-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 356/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35501 To 35600 And 35505A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35505A and removed from the Lot/Batch							
35501	Pass	35502	Pass	35503	Pass	35504	Pass
35505	Pass	35506	Pass	35507	Pass	35508	Pass
35509	Pass	35510	Pass	35511	Pass	35512	Pass
35513	Pass	35514	Pass	35515	Pass	35516	Pass
35517	Pass	35518	Pass	35519	Pass	35520	Pass
35521	Pass	35522	Pass	35523	Pass	35524	Pass
35525	Pass	35526	Pass	35527	Pass	35528	Pass
35529	Pass	35530	Pass	35531	Pass	35532	Pass
35533	Pass	35534	Pass	35535	Pass	35536	Pass
35537	Pass	35538	Pass	35539	Pass	35540	Pass
35541	Pass	35542	Pass	35543	Pass	35544	Pass
35545	Pass	35546	Pass	35547	Pass	35548	Pass
35549	Pass	35550	Pass	35551	Pass	35552	Pass
35553	Pass	35554	Pass	35555	Pass	35556	Pass
35557	Pass	35558	Pass	35559	Pass	35560	Pass
35561	Pass	35562	Pass	35563	Pass	35564	Pass
35565	Pass	35566	Pass	35567	Pass	35568	Pass
35569	Pass	35570	Pass	35571	Pass	35572	Pass
35573	Pass	35574	Pass	35575	Pass	35576	Pass
35577	Pass	35578	Pass	35579	Pass	35580	Pass
35581	Pass	35582	Pass	35583	Pass	35584	Pass
35585	Pass	35586	Pass	35587	Pass	35588	Pass
35589	Pass	35590	Pass	35591	Pass	35592	Pass
35593	Pass	35594	Pass	35595	Pass	35596	Pass
35597	Pass	35598	Pass	35599	Pass	35600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory