

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A90/RQ/271/25      | Model No.: KFARQ-6-90%                                          | Date: 27-10-2025 |
| Type and Capacity of Extinguisher | : KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ90%6 271/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 27001 To 27100 And 27005A                                     |                  |
| Month of Manufacturing            | : Oct/25                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 27005A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 27001                                                         | Pass   | 27002    | Pass   | 27003    | Pass   | 27004    | Pass   |
| 27005                                                         | Pass   | 27006    | Pass   | 27007    | Pass   | 27008    | Pass   |
| 27009                                                         | Pass   | 27010    | Pass   | 27011    | Pass   | 27012    | Pass   |
| 27013                                                         | Pass   | 27014    | Pass   | 27015    | Pass   | 27016    | Pass   |
| 27017                                                         | Pass   | 27018    | Pass   | 27019    | Pass   | 27020    | Pass   |
| 27021                                                         | Pass   | 27022    | Pass   | 27023    | Pass   | 27024    | Pass   |
| 27025                                                         | Pass   | 27026    | Pass   | 27027    | Pass   | 27028    | Pass   |
| 27029                                                         | Pass   | 27030    | Pass   | 27031    | Pass   | 27032    | Pass   |
| 27033                                                         | Pass   | 27034    | Pass   | 27035    | Pass   | 27036    | Pass   |
| 27037                                                         | Pass   | 27038    | Pass   | 27039    | Pass   | 27040    | Pass   |
| 27041                                                         | Pass   | 27042    | Pass   | 27043    | Pass   | 27044    | Pass   |
| 27045                                                         | Pass   | 27046    | Pass   | 27047    | Pass   | 27048    | Pass   |
| 27049                                                         | Pass   | 27050    | Pass   | 27051    | Pass   | 27052    | Pass   |
| 27053                                                         | Pass   | 27054    | Pass   | 27055    | Pass   | 27056    | Pass   |
| 27057                                                         | Pass   | 27058    | Pass   | 27059    | Pass   | 27060    | Pass   |
| 27061                                                         | Pass   | 27062    | Pass   | 27063    | Pass   | 27064    | Pass   |
| 27065                                                         | Pass   | 27066    | Pass   | 27067    | Pass   | 27068    | Pass   |
| 27069                                                         | Pass   | 27070    | Pass   | 27071    | Pass   | 27072    | Pass   |
| 27073                                                         | Pass   | 27074    | Pass   | 27075    | Pass   | 27076    | Pass   |
| 27077                                                         | Pass   | 27078    | Pass   | 27079    | Pass   | 27080    | Pass   |
| 27081                                                         | Pass   | 27082    | Pass   | 27083    | Pass   | 27084    | Pass   |
| 27085                                                         | Pass   | 27086    | Pass   | 27087    | Pass   | 27088    | Pass   |
| 27089                                                         | Pass   | 27090    | Pass   | 27091    | Pass   | 27092    | Pass   |
| 27093                                                         | Pass   | 27094    | Pass   | 27095    | Pass   | 27096    | Pass   |
| 27097                                                         | Pass   | 27098    | Pass   | 27099    | Pass   | 27100    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**