

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/357/25	Model No.: MARQ-6-50%	Date: 12-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 357/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35601 To 35700 And 35605A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35605A and removed from the Lot/Batch							
35601	Pass	35602	Pass	35603	Pass	35604	Pass
35605	Pass	35606	Pass	35607	Pass	35608	Pass
35609	Pass	35610	Pass	35611	Pass	35612	Pass
35613	Pass	35614	Pass	35615	Pass	35616	Pass
35617	Pass	35618	Pass	35619	Pass	35620	Pass
35621	Pass	35622	Pass	35623	Pass	35624	Pass
35625	Pass	35626	Pass	35627	Pass	35628	Pass
35629	Pass	35630	Pass	35631	Pass	35632	Pass
35633	Pass	35634	Pass	35635	Pass	35636	Pass
35637	Pass	35638	Pass	35639	Pass	35640	Pass
35641	Pass	35642	Pass	35643	Pass	35644	Pass
35645	Pass	35646	Pass	35647	Pass	35648	Pass
35649	Pass	35650	Pass	35651	Pass	35652	Pass
35653	Pass	35654	Pass	35655	Pass	35656	Pass
35657	Pass	35658	Pass	35659	Pass	35660	Pass
35661	Pass	35662	Pass	35663	Pass	35664	Pass
35665	Pass	35666	Pass	35667	Pass	35668	Pass
35669	Pass	35670	Pass	35671	Pass	35672	Pass
35673	Pass	35674	Pass	35675	Pass	35676	Pass
35677	Pass	35678	Pass	35679	Pass	35680	Pass
35681	Pass	35682	Pass	35683	Pass	35684	Pass
35685	Pass	35686	Pass	35687	Pass	35688	Pass
35689	Pass	35690	Pass	35691	Pass	35692	Pass
35693	Pass	35694	Pass	35695	Pass	35696	Pass
35697	Pass	35698	Pass	35699	Pass	35700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory