

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/069/25

Model No.: KFKHQ-6

Date: 29-08-2025

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 069/25

Batch Quantity : 10 Nos.

Serial Numbers : 00681 To 690

Month of Manufacturing : Aug/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
681	Pass	682	Pass	683	Pass	684	Pass
685	Pass	686	Pass	687	Pass	688	Pass
689	Pass	690	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**