

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/185/25	Model No.: KMCRQ-10	Date: 09-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 185/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01841 To 1850	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01841 To 1850 and removed from the Lot/Batch							
1841	Pass	1842	Pass	1843	Pass	1844	Pass
1845	Pass	1846	Pass	1847	Pass	1848	Pass
1849	Pass	1850	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory