

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/361/25	Model No.: MARQ-6-50%	Date: 15-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 361/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36001 To 36100 And 36005A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36005A and removed from the Lot/Batch							
36001	Pass	36002	Pass	36003	Pass	36004	Pass
36005	Pass	36006	Pass	36007	Pass	36008	Pass
36009	Pass	36010	Pass	36011	Pass	36012	Pass
36013	Pass	36014	Pass	36015	Pass	36016	Pass
36017	Pass	36018	Pass	36019	Pass	36020	Pass
36021	Pass	36022	Pass	36023	Pass	36024	Pass
36025	Pass	36026	Pass	36027	Pass	36028	Pass
36029	Pass	36030	Pass	36031	Pass	36032	Pass
36033	Pass	36034	Pass	36035	Pass	36036	Pass
36037	Pass	36038	Pass	36039	Pass	36040	Pass
36041	Pass	36042	Pass	36043	Pass	36044	Pass
36045	Pass	36046	Pass	36047	Pass	36048	Pass
36049	Pass	36050	Pass	36051	Pass	36052	Pass
36053	Pass	36054	Pass	36055	Pass	36056	Pass
36057	Pass	36058	Pass	36059	Pass	36060	Pass
36061	Pass	36062	Pass	36063	Pass	36064	Pass
36065	Pass	36066	Pass	36067	Pass	36068	Pass
36069	Pass	36070	Pass	36071	Pass	36072	Pass
36073	Pass	36074	Pass	36075	Pass	36076	Pass
36077	Pass	36078	Pass	36079	Pass	36080	Pass
36081	Pass	36082	Pass	36083	Pass	36084	Pass
36085	Pass	36086	Pass	36087	Pass	36088	Pass
36089	Pass	36090	Pass	36091	Pass	36092	Pass
36093	Pass	36094	Pass	36095	Pass	36096	Pass
36097	Pass	36098	Pass	36099	Pass	36100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory