

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/347/25	Model No.: KFARQ-6-50%	Date: 12-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 347/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 34601 To 34700 And 34605A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 34605A and removed from the Lot/Batch							
34601	Pass	34602	Pass	34603	Pass	34604	Pass
34605	Pass	34606	Pass	34607	Pass	34608	Pass
34609	Pass	34610	Pass	34611	Pass	34612	Pass
34613	Pass	34614	Pass	34615	Pass	34616	Pass
34617	Pass	34618	Pass	34619	Pass	34620	Pass
34621	Pass	34622	Pass	34623	Pass	34624	Pass
34625	Pass	34626	Pass	34627	Pass	34628	Pass
34629	Pass	34630	Pass	34631	Pass	34632	Pass
34633	Pass	34634	Pass	34635	Pass	34636	Pass
34637	Pass	34638	Pass	34639	Pass	34640	Pass
34641	Pass	34642	Pass	34643	Pass	34644	Pass
34645	Pass	34646	Pass	34647	Pass	34648	Pass
34649	Pass	34650	Pass	34651	Pass	34652	Pass
34653	Pass	34654	Pass	34655	Pass	34656	Pass
34657	Pass	34658	Pass	34659	Pass	34660	Pass
34661	Pass	34662	Pass	34663	Pass	34664	Pass
34665	Pass	34666	Pass	34667	Pass	34668	Pass
34669	Pass	34670	Pass	34671	Pass	34672	Pass
34673	Pass	34674	Pass	34675	Pass	34676	Pass
34677	Pass	34678	Pass	34679	Pass	34680	Pass
34681	Pass	34682	Pass	34683	Pass	34684	Pass
34685	Pass	34686	Pass	34687	Pass	34688	Pass
34689	Pass	34690	Pass	34691	Pass	34692	Pass
34693	Pass	34694	Pass	34695	Pass	34696	Pass
34697	Pass	34698	Pass	34699	Pass	34700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory