

HYDRO PRESSURE TEST

TC No.: HPT/MA2/A40/RQ/014/25	Model No.: MARQ-2-40%	Date: 17-11-2025
Type and Capacity of Extinguisher	: MARQ-2-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: MARQ40%2 014/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01301 To 1400 And 1305A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1305A and removed from the Lot/Batch							
1301	Pass	1302	Pass	1303	Pass	1304	Pass
1305	Pass	1306	Pass	1307	Pass	1308	Pass
1309	Pass	1310	Pass	1311	Pass	1312	Pass
1313	Pass	1314	Pass	1315	Pass	1316	Pass
1317	Pass	1318	Pass	1319	Pass	1320	Pass
1321	Pass	1322	Pass	1323	Pass	1324	Pass
1325	Pass	1326	Pass	1327	Pass	1328	Pass
1329	Pass	1330	Pass	1331	Pass	1332	Pass
1333	Pass	1334	Pass	1335	Pass	1336	Pass
1337	Pass	1338	Pass	1339	Pass	1340	Pass
1341	Pass	1342	Pass	1343	Pass	1344	Pass
1345	Pass	1346	Pass	1347	Pass	1348	Pass
1349	Pass	1350	Pass	1351	Pass	1352	Pass
1353	Pass	1354	Pass	1355	Pass	1356	Pass
1357	Pass	1358	Pass	1359	Pass	1360	Pass
1361	Pass	1362	Pass	1363	Pass	1364	Pass
1365	Pass	1366	Pass	1367	Pass	1368	Pass
1369	Pass	1370	Pass	1371	Pass	1372	Pass
1373	Pass	1374	Pass	1375	Pass	1376	Pass
1377	Pass	1378	Pass	1379	Pass	1380	Pass
1381	Pass	1382	Pass	1383	Pass	1384	Pass
1385	Pass	1386	Pass	1387	Pass	1388	Pass
1389	Pass	1390	Pass	1391	Pass	1392	Pass
1393	Pass	1394	Pass	1395	Pass	1396	Pass
1397	Pass	1398	Pass	1399	Pass	1400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory