

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/288/25	Model No.: KFARQ-6-90%	Date: 14-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 288/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28701 To 28800 And 28705A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28705A and removed from the Lot/Batch							
28701	Pass	28702	Pass	28703	Pass	28704	Pass
28705	Pass	28706	Pass	28707	Pass	28708	Pass
28709	Pass	28710	Pass	28711	Pass	28712	Pass
28713	Pass	28714	Pass	28715	Pass	28716	Pass
28717	Pass	28718	Pass	28719	Pass	28720	Pass
28721	Pass	28722	Pass	28723	Pass	28724	Pass
28725	Pass	28726	Pass	28727	Pass	28728	Pass
28729	Pass	28730	Pass	28731	Pass	28732	Pass
28733	Pass	28734	Pass	28735	Pass	28736	Pass
28737	Pass	28738	Pass	28739	Pass	28740	Pass
28741	Pass	28742	Pass	28743	Pass	28744	Pass
28745	Pass	28746	Pass	28747	Pass	28748	Pass
28749	Pass	28750	Pass	28751	Pass	28752	Pass
28753	Pass	28754	Pass	28755	Pass	28756	Pass
28757	Pass	28758	Pass	28759	Pass	28760	Pass
28761	Pass	28762	Pass	28763	Pass	28764	Pass
28765	Pass	28766	Pass	28767	Pass	28768	Pass
28769	Pass	28770	Pass	28771	Pass	28772	Pass
28773	Pass	28774	Pass	28775	Pass	28776	Pass
28777	Pass	28778	Pass	28779	Pass	28780	Pass
28781	Pass	28782	Pass	28783	Pass	28784	Pass
28785	Pass	28786	Pass	28787	Pass	28788	Pass
28789	Pass	28790	Pass	28791	Pass	28792	Pass
28793	Pass	28794	Pass	28795	Pass	28796	Pass
28797	Pass	28798	Pass	28799	Pass	28800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory