

HYDRO PRESSURE TEST

TC No.: HPT/F60/RQ/007/25	Model No.: KFMRQ-60	Date: 26-06-2025
Type and Capacity of Extinguisher	: KFMRQ-60-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 60 Ltr.	
Batch Number	: KFMRQ60 007/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00301 To 350	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No. 5A and which is removed from the batch (batch)							
301	Pass	302	Pass	303	Pass	304	Pass
305	Pass	306	Pass	307	Pass	308	Pass
309	Pass	310	Pass	311	Pass	312	Pass
313	Pass	314	Pass	315	Pass	316	Pass
317	Pass	318	Pass	319	Pass	320	Pass
321	Pass	322	Pass	323	Pass	324	Pass
325	Pass	326	Pass	327	Pass	328	Pass
329	Pass	330	Pass	331	Pass	332	Pass
333	Pass	334	Pass	335	Pass	336	Pass
337	Pass	338	Pass	339	Pass	340	Pass
341	Pass	342	Pass	343	Pass	344	Pass
345	Pass	346	Pass	347	Pass	348	Pass
349	Pass	350	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory