

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/A50/RQ/053/25	Model No.: KMPRQ-10-50%	Date: 25-12-2025
Type and Capacity of Extinguisher	: KMPRQ-10-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMPRQ50%10 053/25	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 01041 To 1060	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01041 To 1060 and removed from the Lot/Batch							
1041	Pass	1042	Pass	1043	Pass	1044	Pass
1045	Pass	1046	Pass	1047	Pass	1048	Pass
1049	Pass	1050	Pass	1051	Pass	1052	Pass
1053	Pass	1054	Pass	1055	Pass	1056	Pass
1057	Pass	1058	Pass	1059	Pass	1060	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory