

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/190/25	Model No.: MARQ-6-50%	Date: 14-06-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 190/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18901 To 19000 And 18905A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18905A and removed from the Lot/Batch							
18901	Pass	18902	Pass	18903	Pass	18904	Pass
18905	Pass	18906	Pass	18907	Pass	18908	Pass
18909	Pass	18910	Pass	18911	Pass	18912	Pass
18913	Pass	18914	Pass	18915	Pass	18916	Pass
18917	Pass	18918	Pass	18919	Pass	18920	Pass
18921	Pass	18922	Pass	18923	Pass	18924	Pass
18925	Pass	18926	Pass	18927	Pass	18928	Pass
18929	Pass	18930	Pass	18931	Pass	18932	Pass
18933	Pass	18934	Pass	18935	Pass	18936	Pass
18937	Pass	18938	Pass	18939	Pass	18940	Pass
18941	Pass	18942	Pass	18943	Pass	18944	Pass
18945	Pass	18946	Pass	18947	Pass	18948	Pass
18949	Pass	18950	Pass	18951	Pass	18952	Pass
18953	Pass	18954	Pass	18955	Pass	18956	Pass
18957	Pass	18958	Pass	18959	Pass	18960	Pass
18961	Pass	18962	Pass	18963	Pass	18964	Pass
18965	Pass	18966	Pass	18967	Pass	18968	Pass
18969	Pass	18970	Pass	18971	Pass	18972	Pass
18973	Pass	18974	Pass	18975	Pass	18976	Pass
18977	Pass	18978	Pass	18979	Pass	18980	Pass
18981	Pass	18982	Pass	18983	Pass	18984	Pass
18985	Pass	18986	Pass	18987	Pass	18988	Pass
18989	Pass	18990	Pass	18991	Pass	18992	Pass
18993	Pass	18994	Pass	18995	Pass	18996	Pass
18997	Pass	18998	Pass	18999	Pass	19000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory