

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/368/25	Model No.: MARQ-6-50%	Date: 20-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 368/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 36701 To 36800 And 36705A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 36705A and removed from the Lot/Batch							
36701	Pass	36702	Pass	36703	Pass	36704	Pass
36705	Pass	36706	Pass	36707	Pass	36708	Pass
36709	Pass	36710	Pass	36711	Pass	36712	Pass
36713	Pass	36714	Pass	36715	Pass	36716	Pass
36717	Pass	36718	Pass	36719	Pass	36720	Pass
36721	Pass	36722	Pass	36723	Pass	36724	Pass
36725	Pass	36726	Pass	36727	Pass	36728	Pass
36729	Pass	36730	Pass	36731	Pass	36732	Pass
36733	Pass	36734	Pass	36735	Pass	36736	Pass
36737	Pass	36738	Pass	36739	Pass	36740	Pass
36741	Pass	36742	Pass	36743	Pass	36744	Pass
36745	Pass	36746	Pass	36747	Pass	36748	Pass
36749	Pass	36750	Pass	36751	Pass	36752	Pass
36753	Pass	36754	Pass	36755	Pass	36756	Pass
36757	Pass	36758	Pass	36759	Pass	36760	Pass
36761	Pass	36762	Pass	36763	Pass	36764	Pass
36765	Pass	36766	Pass	36767	Pass	36768	Pass
36769	Pass	36770	Pass	36771	Pass	36772	Pass
36773	Pass	36774	Pass	36775	Pass	36776	Pass
36777	Pass	36778	Pass	36779	Pass	36780	Pass
36781	Pass	36782	Pass	36783	Pass	36784	Pass
36785	Pass	36786	Pass	36787	Pass	36788	Pass
36789	Pass	36790	Pass	36791	Pass	36792	Pass
36793	Pass	36794	Pass	36795	Pass	36796	Pass
36797	Pass	36798	Pass	36799	Pass	36800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory