

HELIUM LEAK DETECTION TEST

TC No.: HLD/MOD2/CA/HQ/004/25	Model No.: KMCHQ-2-FE36	Date: 25-09-2025
Type and Capacity of Extinguisher	: KMCHQ-2-FE36-Kanex Modular Clean Agent Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KMCHQ2 004/25	
Batch Quantity	: 20 Nos.	
Serial Numbers	: 00061 To 80	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
61	Pass	62	Pass	63	Pass	64	Pass
65	Pass	66	Pass	67	Pass	68	Pass
69	Pass	70	Pass	71	Pass	72	Pass
73	Pass	74	Pass	75	Pass	76	Pass
77	Pass	78	Pass	79	Pass	80	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**