

HELIUM LEAK DETECTION TEST

TC No.: HLD/A3/K/HQ/019/25

Model No.: KFKHQ-3

Date: 09-06-2025

Type and Capacity of Extinguisher : KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.

Batch Number : KFKHQ3 019/25

Batch Quantity : 10 Nos.

Serial Numbers : 00181 To 190

Month of Manufacturing : Jun/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
181	Pass	182	Pass	183	Pass	184	Pass
185	Pass	186	Pass	187	Pass	188	Pass
189	Pass	190	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**